Multifamily Duct Blaster Testing Sheet

Date:

Builder/Developer:	
Project:	
Section:	
Inspector:	

Duct Blaster Equations:
Ring 3: 6.33x/Pa
Ring 2: 15.8x/Pa
Ring 1: 41.42x/Pa
Open: 108.5x/Pa

	Total Duct Leakage (Pressurize Ducts to 25Pa)				**Duct Leakage to Outside Building Envelope (Pressurize Unit to 25Pa First)**				
Unit # / Type	**Floor Area (sqft)**	**Ring** Open, 1, 2, or 3	**Fan Pressure** (Pa)	**Fan Flow** (CFM25)	**% Leakage** CFM25/Floor Area	**Ring** Open, 1, 2, or 3	**Fan Pressure** (Pa)	**Fan Flow** (CFM25)	**% Leakage** CFM25/Floor Area	**Notes:**
					0.0%				0.0%	
					0.0%				0.0%	
					0.0%				0.0%	
					0.0%				0.0%	
					0.0%				0.0%	
					0.0%				0.0%	
					0.0%				0.0%	
					0.0%				0.0%	
					0.0%				0.0%	

Refrigerator model #:		Window U-Value:	
Dishwasher model #:		Window SHGC:	
HVAC Indoor Unit model #:		# Pin-Based Fixtures:	
Outdoor Unit model #:		# CFLs:	
Water Heater model #:		# Total Fixtures:	

www.earthcrafthouse.com
echinfo@earthcrafthouse.com
241 Pine Street NE Atlanta GA 30308
Phone 404.604.3636
Fax 404.604.3681

PRINT SUBMIT